

MODEL : 2060R - NC / RF - 05 / 06 / 07 / 08 - LTE / D10 / D01 / D2B / D3 - 01


IMPORTANT - READ CAREFULLY BEFORE INSTALLING FIXTURE. RETAIN THESE INSTRUCTIONS FOR FUTURE REFERENCE.

THIS PRODUCT MUST BE INSTALLED IN ACCORDANCE WITH THE NATIONAL ELECTRICAL CODE AND ALL APPLICABLE LOCAL CODES, BY A PERSON FAMILIAR WITH THE CONSTRUCTION AND OPERATION OF THE PRODUCT, AND THE HAZARDS INVOLVED. PROPER GROUNDING IS REQUIRED FOR SAFETY.

NEW CONSTRUCTION WITH PLASTER FRAME (NC) / REMODEL (RF) INTEGRAL DRIVER (120V / 120-277V) DIMMING 0-10V (1%) - LUTRON HI-LUME® (1% EcoSystem™ / 1% 2-WIRE)



- A- LOOSEN THE CONNECTION BOX PHILLIPS SCREW AND SLIDE THE COVER OPEN.
B- INSTALL BX CABLE (**NOT INCLUDED**) USING BX CONNECTOR (**INCLUDED**). LEAVE AT LEAST 6" OF WIRE IN THE BOX.
C- MAKE ALL NECESSARY CONNECTIONS (**SEE WIRING DIAGRAM**) USING TWIST CONNECTORS (**NOT INCLUDED**). ***DAISY CHAIN READY.**
D- CLOSE THE CONNECTION BOX COVER AND TIGHTEN THE PHILLIPS SCREW.
E- MAKE THE CUT-OUT OPENING (**SEE DIMENSIONS BELOW**).
F- INSERT THE DRIVER INTO THE CUT-OUT.
G- HOLD THE (2) CLIPS UPWARD AND INSERT FIXTURE INTO THE CUT-OUT.
***FOR MAINTENANCE, PULL THE FIXTURE OUT OF THE CUT-OUT.**

A + B + C





WIRING DIAGRAM

DIMMING TRIAC (D3)
120V ONLY
DAISY CHAIN READY




DIMMING 0-10V (D01)
EcoSystem™ (D2B)
120-277V
DAISY CHAIN READY



If the wires for dimming are not used, protect wire ends with twist connectors.

E + F + G




Model	Plaster Frame	Cut-out dimensions (A)	Ceiling thickness	Clearance
2060R-05	BN-2060-05-NC	Ø4¼" (Ø105mm)	1/8"-13/16" (3-20mm)	6½" (165mm)
2060R-06	BN-2060-06-NC	Ø5⅝" (Ø135mm)		5" (127mm)
2060R-07	BN-2060-07-NC	Ø7⅞" (Ø185mm)		4½" (114mm)
2060R-08	BN-2060-08-NC	Ø8½" (Ø215mm)		3½" (89mm)

NEW CONSTRUCTION WITH PLASTER FRAME (NC) / REMODEL (RF) INTEGRAL DRIVER (120V) DIMMING TRIAC / ELV (15%)



- A- LOOSEN THE CONNECTION BOX PHILLIPS SCREW AND OPEN IT.
 B- INSTALL BX CABLE (**NOT INCLUDED**) USING BX CONNECTOR (**INCLUDED**). LEAVE AT LEAST 6" OF WIRE IN THE BOX.
 C- MAKE ALL NECESSARY CONNECTIONS (**SEE WIRING DIAGRAM**) USING TWIST CONNECTORS (**NOT INCLUDED**). ***DAISY CHAIN READY.**
 D- CLOSE THE CONNECTION BOX AND TIGHTEN THE PHILLIPS SCREW.
 E- MAKE THE CUT-OUT OPENING (**SEE DIMENSIONS BELOW**).
 F- INSERT THE DRIVER INTO THE CUT-OUT.
 G- HOLD THE (2) CLIPS UPWARD AND INSERT FIXTURE INTO THE CUT-OUT.
***FOR MAINTENANCE, PULL THE FIXTURE OUT OF THE CUT-OUT.**

A + B + C




WIRING DIAGRAM

DIMMING TRIAC/ELV (LTE)
120V ONLY
DAISY CHAIN READY



E + F + G




Model	Plaster Frame	Cut-out dimensions (A)	Ceiling thickness	Clearance
2060R-05	BN-2060-05-NC	Ø4¼" (Ø105mm)	⅛"-1⅜" (3-20mm)	6½" (165mm)
2060R-06	BN-2060-06-NC	Ø5⅝" (Ø135mm)		5" (127mm)
2060R-07	BN-2060-07-NC	Ø7⅜" (Ø185mm)	⅛"-1⅜" (3-20mm)	4½" (114mm)
2060R-08	BN-2060-08-NC	Ø8½" (Ø215mm)		3½" (89mm)

NEW CONSTRUCTION WITH PLASTER FRAME (NC) / REMODEL (RF) **INTEGRAL DRIVER (120-277V)** **DIMMING 0-10V (15%)**

- A- LOOSEN THE (2) PHILLIPS SCREWS TO SLIDE THE DIMMING CIRCUIT BOX COVER OPEN AND OPEN THE BRANCH CIRCUIT BOX.
 B- INSTALL BX CABLE (**NOT INCLUDED**) USING BX CONNECTOR (**INCLUDED**). LEAVE AT LEAST 6" OF WIRE IN THE BOX.
 C- MAKE ALL NECESSARY CONNECTIONS (**SEE WIRING DIAGRAM**) USING TWIST CONNECTORS (**NOT INCLUDED**). ***DAISY CHAIN READY.**
 D- SLIDE THE DIMMING CIRCUIT BOX COVER BACK ON, CLOSE THE BRANCH CIRCUIT BOX AND TIGHTEN THE PHILLIPS SCREWS.
 E- MAKE THE CUT-OUT OPENING (**SEE DIMENSIONS BELOW**).
 F- INSERT THE DRIVER INTO THE CUT-OUT.
 G- HOLD THE (2) CLIPS UPWARD AND INSERT FIXTURE INTO THE CUT-OUT.
***FOR MAINTENANCE, PULL THE FIXTURE OUT OF THE CUT-OUT.**


A + B + C



WIRING DIAGRAM

DIMMING 120-277V
 0-10V (D10)

DAISY CHAIN READY




FIXTURE CABLES



If the wires for dimming are not used, protect wire ends with twist connectors.


E + F + G



Model	Plaster Frame	Cut-out dimensions (A)	Ceiling thickness	Clearance
2060R-05	BN-2060-05-NC	Ø4¼" (Ø105mm)	⅞"-1⅞" (3-20mm)	6½" (165mm)
2060R-06	BN-2060-06-NC	Ø5⅝" (Ø135mm)		5" (127mm)
2060R-07	BN-2060-07-NC	Ø7⅜" (Ø185mm)		4½" (114mm)
2060R-08	BN-2060-08-NC	Ø8½" (Ø215mm)		3½" (89mm)


DECORATIVE RING INSTALLATION (NC) (207X-XX-XX)

HOLD THE FIXTURE'S (2) CLIPS UPWARD AND SET THE RING ONTO THE FIXTURE.



NEW CONSTRUCTION PLASTER FRAME INSTALLATION (NC)

- A- ENGAGE THE (4) HANGER BARS IN BOX SLOTS AVAILABLE AND CONNECT THEM TOGETHER.
- B- FASTEN HANGER BARS TO CEILING BRACE WITH APPROPRIATE #8 SCREWS (**NOT INCLUDED**). THE PLASTER FRAME MUST BE FLUSH WITH CEILING BRACE AND INSURE THE SMALL FOLDED TABS ARE PLACED UNDER THE CEILING BRACES.

A**B**