



IMPORTANT - READ CAREFULLY BEFORE INSTALLING FIXTURE. RETAIN THESE INSTRUCTIONS FOR FUTURE REFERENCE. THIS PRODUCT MUST BE INSTALLED IN ACCORDANCE WITH THE NATIONAL ELECTRICAL CODE AND ALL APPLICABLE LOCAL CODES, BY A PERSON FAMILIAR WITH THE CONSTRUCTION AND OPERATION OF THE PRODUCT, AND THE HAZARDS INVOLVED. PROPER GROUNDING IS REQUIRED FOR SAFETY.


INSTALLATION WITH DIRECT FEED - REMOTE DRIVER (DF-REM)


- A- PREPARE INSTALLATION SURFACE USING THE DIMENSIONS BELOW.
- B- UNSCREW THE (4) SET SCREWS WITH AN ALLEN KEY (INCLUDED) TO REMOVE THE FIXTURE COVER FROM THE FIXTURE BASE. DO NOT COMPLETELY REMOVE THE SET SCREWS.
- C- INSERT WIRE THROUGH THE FIXTURE BASE LIQUIDTIGHT CONNECTOR (INCLUDED). TO INSURE LIQUIDTIGHT SEAL, USE SHEATHED WIRES.
- D- SECURE THE FIXTURE BASE TO THE SURFACE USING THE APPROPRIATE (2) SCREWS (NOT INCLUDED). (MAX #10 Ø3/16")
- E- MAKE WIRE CONNECTIONS (FOLLOWING POLARITY MARKINGS) USING THE CONNECTION BLOC.
- F- FASTEN THE FIXTURE COVER TO THE FIXTURE BASE WITH THE SET SCREWS USING AN ALLEN KEY (INCLUDED).

Α









SISTEMALUX


P.: 514.523.1339 F.: 514.525.6107 www.sistemalux.com





INSTALLATION WITH 4" JUNCTION BOX - REMOTE DRIVER (JB-REM)


- A- PREPARE INSTALLATION SURFACE USING THE DIMENSIONS BELOW.
- B- UNSCREW THE (4) SET SCREWS WITH AN ALLEN KEY (INCLUDED) TO REMOVE THE FIXTURE COVER FROM THE FIXTURE BASE. DO NOT COMPLETELY REMOVE THE SET SCREWS.
- C- INSTALL THE MOUNTING PLATE ON THE JUNCTION BOX USING (2) PHILLIPS SCREWS (NOT INCLUDED) AND PASS THE WIRES THROUGH.
- D- MAKE WIRE CONNECTIONS (FOLLOWING POLARITY MARKINGS) USING WATERTIGHT CONNECTORS (NOT INCLUDED). ONCE CONNECTED, PUSH WIRES BACK INTO THE JUNCTION BOX.
- E- SECURE THE FIXTURE BASE TO THE MOUNTING PLATE USING THE (2) PHILLIPS SCREWS (8-32) (INCLUDED).
- F- FASTEN THE FIXTURE COVER TO THE FIXTURE BASE WITH THE SET SCREWS USING AN ALLEN KEY (INCLUDED).

Α









SISTEMALUX


P.: 514.523.1339 F.: 514.525.6107 www.sistemalux.com





INSTALLATION WITH 4" JUNCTION BOX - 120-277V (JB-UNV) DIMMING 0-10V (D10)


- A- PREPARE INSTALLATION SURFACE USING THE DIMENSIONS BELOW.
- B- UNSCREW THE (4) SET SCREWS WITH AN ALLEN KEY (INCLUDED) TO REMOVE THE FIXTURE COVER FROM THE FIXTURE BASE. DO NOT COMPLETELY REMOVE THE SET SCREWS.
- C- INSTALL THE MOUNTING PLATE ON THE JUNCTION BOX USING (2) PHILLIPS SCREWS (NOT INCLUDED) AND PASS THE WIRES THROUGH.
- D- MAKE WIRE CONNECTIONS (FOLLOWING POLARITY MARKINGS) USING WATERTIGHT CONNECTORS (NOT INCLUDED). ONCE CONNECTED, PUSH WIRES BACK INTO THE JUNCTION BOX.
- E- SECURE THE FIXTURE BASE TO THE MOUNTING PLATE USING THE (2) PHILLIPS SCREWS (8-32) (INCLUDED).
- F- FASTEN THE FIXTURE COVER TO THE FIXTURE BASE WITH THE SET SCREWS USING AN ALLEN KEY (INCLUDED).

Α









INS-421

Last update: March 25, 2022


PAGE: 4 of 5





INSTALLATION FLUSH MOUNT RECESSED WITH BACK BOX - REMOTE DRIVER (FM-REM)

- A- USE NAILS (NOT INCLUDED) TO FIX THE BACK BOX MALE PART TO THE PLYWOOD.
- B- ASSEMBLE THE BACK BOX MALE AND FEMALE PARTS TOGETHER USING SCREWS (NOT INCLUDED).
- C- INSERT A CONDUIT (NOT INCLUDED) IN THE APPROPRIATE KNOCK OUT (SEE DIMENSIONS BELOW).

Α









SISTEMALUX





INSTALLATION FLUSH MOUNT RECESSED WITH BACK BOX - REMOTE DRIVER (FM-REM)

- D- POUR CONCRETE IN THE FORMWORK WHERE THE BACK BOX IS PLACED. WAIT FOR THE CONCRETE TO DRY. WHEN REMOVING THE FORMWORK, PULL THE MALE PART OFF OF THE BACK BOX.
- E- INSTALL (2) BALLSTUDS (INCLUDED) ON THE FIXTURE.
- F- MAKE WIRE CONNECTIONS (FOLLOWING POLARITY MARKINGS) USING WATERTIGHT CONNECTORS (**NOT INCLUDED**). PUSH THE FIXTURE IN THE BACK BOX UNTIL IT CLICKS IN PLACE.









SISTEMALUX

Last update: March 25, 2022